

**Table 2.10. Fuel-Switching Capacity: From Natural Gas to Petroleum Liquids, by Type of Prime Mover, 2005**  
(Count, Megawatts)

Prime Mover Type	Number of Generators	Net Summer Capacity	Net Summer Capacity Reported as Having No Regulatory Limits on use of Petroleum Liquids <sup>1</sup>
Steam Generator.....	244	33,193	15,553
Combined Cycle.....	388	33,358	4,058
Internal Combustion.....	324	900	293
Gas Turbine.....	899	50,764	11,295
All Fuel Switchable Prime Movers.....	1,855	118,216	31,200

<sup>1</sup> Distillate fuel oil (all diesel and No. 1, No. 2, and No. 4 fuel oils), residual fuel oil (No. 5 and No. 6 fuel oils and bunker C fuel oil), jet fuel, kerosene, and waste oil.

Source: Energy Information Administration, Form EIA-860, "Annual Electric Generator Report."